

MAKLUMAT SPESIFIKASI ITEM

www.fineprocurementplus.uitm.edu.my



MAKLUMAT SPESIFIKASI ITEM

No Pelawaan	: UiTM/B4/PER/SHR/B/0625/0006
Butiran Tawaran	: CADANGAN MENGHANTAR, MEMBEKAL, MEMASANG DAN MENGUJILARI BAGI KERJA KERJA
Keterangan Item	: 0602010100019 : Uninterruptible Power Supply (UPS)
Nama Spesifikasi	: Bateri Uninterruptible Power Supply (UPS) KSB
Kuantiti	: 544.000

Butiran Keperluan

1 GENERAL REQUIREMENT

- I The proposed equipment must have a local service center near UiTM Sungai Buloh to provide full technical support and maintenance.
- II Catalog(s) must be attached upon submission of tender documents.
- III The component listed below must be able to be integrated and work as one system.

Calit

☐☐☐

Tawaran Syarikat

2 BATTERY SYSTEM REQUIREMENT

- I **Nominal Voltage:** 12V
- II **Capacity:** 7.6Ah
- III Quantity Battery : 544 Unit

☐☐☐

Butiran Keperluan**Calit****Tawaran Syarikat**

IV Dimension +/- 151 x 95 x 65 (L x W x H)mm

☐

V Re-arrange load to UPS required

☐**3 SUPPORT & WARRANTY**

I Warranty For Equipment is expected to be at least one (1) year.

☐

II Must provide comprehensive and extensive after sales service on labour and overall parts.

☐

III Must provide warranty letter direct from local or authorized manufacture or distributor on delivery of the equipment.

☐

IV Cost of delivery of the equipment is borne by the supplier

☐**4 SERVICE**

I Minimum of 2 times preventive maintenance within 1 years. Preventive maintenance must include generate UPS health log report dan batteries health report and able to obtain the dynamic password by authorized certified engineer/principal.

☐**5 SCOPE OF WORK**

I Supplier to provide all material, manpower, instrument and equipment transportation and other necessities required for full and complete installation of new UPS batteries.

☐

II Supplier will responsible to make good any renovating of hacking work, removal of wall/door required for the installation process within same day.

☐

III supplier must ensure completion of batteries installation and able to power up within 1 working day from start work.

☐

IV Supplier will responsible for the cleanliness of technical room upon installation UPS batteries, disposal of dirt, debris and any unwanted construction materials by supplier.

☐**6 TRAINING**

Butiran Keperluan

- I Supplier are required to provide training for the use,maintenance,troubleshoot and repair of the requirement to the staff UiTM.
- II Training should be conducted for five (4) persons of staff or more assigned by UiTM.
- III The duration / time / training syllabus / numbers of participants for the training would be discussed on delivery of the equipment.

Calit

☐

☐

☐

Tawaran Syarikat